

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	General	DSH 0807A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Luminaires system for 230 V	<ul style="list-style-type: none"> - Luminaires system - Extra low voltage - EN 60598-2-23 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>A luminaire is constructed for use with a supporting method as principally specified for “extra low voltage lighting system for filament lamps” (EN 60598-2-23). This luminaire is for 230 V. Can we agree that the appliance is primarily tested according to EN 60598-1 and relevant requirements of EN 60598-2-23?</p>			
Decision			
<p>The luminaire cannot be accepted as a system according to EN 60598-1; only one luminaire with clear connection can be certified.</p>			
Explanatory notes			
<p>---</p>			