

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	11.2.1	DSH 0916A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Creepage distances and clearances at a supply terminal	<ul style="list-style-type: none"> - Lampholders - § 11.2.1 - Supply terminal 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Creepage distances and clearances at a supply terminal shall be measured according to the Figure 24 of the standard. Shall we apply the requirements of the figure to the terminals of lampholders (in fixed luminaires) used as means of connections to the supply?</p>			
Decision			
<p>Yes – even though lampholders were separately approved to the appropriate IEC standard, they shall be mounted in luminaires in accordance with the requirements of the § 11.2.1.</p>			
Explanatory notes			
