

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s):	Tracking No.	Year
EN 60598-1:2015/A1:2018	12.4.2	DSH 0924A	2019
Category:			
LITE			
Subject:	Key words:	Developed by	Approved at
Sleeve for earthing supply cable	<ul style="list-style-type: none"> - Supply cable - Sleeve - Earthing-conductor 	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Can the earthing supply cable be used without a sleeve if the temperature is more than 90°C?</p>			
Decision			
<p>Supply cable needs sleeve also for the earthing-conductor.</p>			
Explanatory notes			
<p>---</p>			