

OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60598-2-2:2012 EN 60598-1:2015/A1:2018	2.11 8	DSH 0933A	2019
Category			
LITE			
Subject	Keywords	Developed by	Approved at
IP protection of recessed parts	- Paragraph 8 - IP classifications - Item 12.3	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>EN 60598-2-2, sub-clause 2.11. The new paragraph may be understood to mean that accessible components mounted on external part of the luminaire within the ceiling space shall have the same IPX-degree as required for the part of the luminaire protruding beneath the ceiling. Is it correct?</p>			
Decision			
<p>This refers only to paragraph 8, protection against electric shock and not to IP classifications.</p>			
Explanatory notes			
<p>---</p>			