

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60598-2-22/2014	22.6.2 – Annex B	DSH 0972B	2019
<b>Category</b>			
LITE			
Subject	Keywords	Developed by	Approved at
Marking	<ul style="list-style-type: none"> <li>- Rest mode</li> <li>- Capital "B"</li> <li>- Emergency luminaire</li> </ul>	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Annex B gives an overview of the classification and marking of emergency luminaires as to their construction. Item c) states that capital "B" is used for emergency luminaires including remote rest mode. What identification has to be used in case there is only rest mode (without remote)?</p>			
Decision			
<p>For rest mode only use also capital "B".</p>			
Explanatory notes			
---			