

## OSM/LUM DECISION SHEET (DSH)

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 61347-1:2015	General	DSH 1014A	2019
<b>Category</b>			
LITE			
Subject	Keywords	Developed by	Approved at
Heating test for convertors	<ul style="list-style-type: none"> <li>- tc value</li> <li>- Independent convertors</li> <li>- Marking</li> </ul>	OSM/LUM-ETF5	2019 ETICS Plenary Meeting
Question			
<p>Convertors must be tested with the case at the tc marked temperature. However independent convertors do not have a tc temperature. How must this test be performed, if no tc temperature is given?</p>			
Decision			
<p>The tc value is also applicable for independent convertors, because the test is related to the tc value. So this marking is not allowed to be ignored for independent convertors.</p>			
Explanatory notes			
<p>---</p>			