

## **OSM/LUM PROVISIONAL DECISION SHEET (PDSH)**

Standard(s) (incl. year)	Subclause(s)	Tracking No.	Year
EN 60570:2003 – A1:2018	3.6	PDSH 2145	2019
Category			
LITE			
Subject	Keywords	Developed by	To be approved at
Adaptor for track system	<ul> <li>Single adaptor</li> <li>Multi adaptor</li> <li>Track system</li> <li>ENEC / CCA</li> </ul>	OSM/LUM-ETF5	2020 ETICS Plenary Meeting
Question			
Decision         The issuing of a CCA Certificate on a single adapter is not allowed.         The CCA Certificate shall be issued on the complete track system.         The issuing of an ENEC Certificate for a single adapter is not allowed (see PD ENEC 301 Annex B).         The ENEC Certificate shall be issued on the complete track system.         Explanatory notes			
Track systems shall exist of at least a track, supply connector, coupler and adapter. All components according to the manufacturer catalogue shall be subject for testing. For a multi-adapter as a single component it is not possible to issue a certificate, as the adapter manufacturer cannot control the dimensions of the essential parts of the third party track.			